




NOTE: ALL JOINTS MUST BE RESTRAINED BACK TO MAIN (ALL-THREAD RODS ARE NOT ACCEPTABLE).

	APPROVED :  HEAD, BUREAU OF WATER AND WASTEWATER	CITY OF BALTIMORE DEPARTMENT OF PUBLIC WORKS BUREAU OF WATER AND WASTEWATER  STANDARD INSTALLATION OF 4" & 6" WATER SUPPLY SERVICES (3", 4", & 6" METERS) WITH TEE AND VALVE (ROADWAY BOX)	ISSUED	REVISED	REVISED
	 DIRECTOR, DEPARTMENT OF PUBLIC WORKS		3 / 2008		
	<b>STANDARD NO. BC 843.01</b>			SCALE : NONE	SHEET 1 OF 1