


**NOTES:**

1. Existing sewer main shall be at least 10 inches in diameter for 6 inch house connections when using a sewer saddle. When sewer main is less than 10" in diameter, then pipe replacement method shall be used as shown on Standard Detail BC 830.18. A manhole shall be used when the house connection is 8" or larger.
2. Contractor shall maintain all flows in accordance with all state and local requirements.
3. When directed by the City, concrete encase saddle connection in accordance with Standard Detail BC 830.04.



APPROVED :  
  
 HEAD, BUREAU OF WATER AND WASTEWATER  
  
 DIRECTOR, DEPARTMENT OF PUBLIC WORKS

**CITY OF BALTIMORE  
 DEPARTMENT OF PUBLIC WORKS  
 BUREAU OF WATER AND WASTEWATER**

**SADDLE INSTALLATION  
 DETAIL FOR NEW HOUSE  
 CONNECTION TO  
 EXISTING SEWER**

ISSUED	REVISED	REVISED
3 / 2008		
<b>STANDARD NO. BC 830.17</b>		
SCALE : NONE		SHEET 1 OF 1